

## VOC Analysis

### Test Report On Paint Type Sample

**Sample Identification:**

Sample #1	Bauwerk Colour Limewash Interior Paint
Sample #2	Bauwerk Colour Limewash Fire Proof Paint
Sample #3	Bauwerk Colour Limewash Exterior Paint

**Samples by:** Client  
**Date Sampled:** 02.01.2014  
**Date Received:** 02.01.2014  
**AHS Sample No.:** 23007260 / 001 – 003

### Test Method

- ASTM D-6886
- VOC analysis as per USEPA SW 846 – 8260B, where the samples are directly purged to analysis by Capillary GC/MS and quantification by comparison against an established 5 point calibration curve.

### Results

Test Parameter	Sample	Units	Results*
Volatile Organic Compounds	1	%	Less Than 0.01
Volatile Organic Compounds	2	%	Less Than 0.01
Volatile Organic Compounds	3	%	Less Than 0.01



**NAEEM ZAIDI, M. Sc.**  
Manager  
Materials Analysis Dept.  
For AL HOTY-STANGER LTD. CO.



**A. N. M. OMAR, M. Sc.**  
Assistant Manager  
Materials Analysis Dept.  
Test Method Variation: NONE